

June 15, 2004

Containment Solutions, Inc.  
Mr. Bill Felts  
5150 Jefferson Chemical Rd.  
Conroe, TX 77301-6834

Our Reference: MH29555

Subject: Single and Double Wall Tanks Sumps for Petroleum Products, Alcohols and  
Alcohol-Gasoline Mixtures


Dear Mr. Felts:

This is to confirm that Containment Solutions, Inc.'s reinforced plastic underground single and double wall sumps have been evaluated by Underwriters Laboratories Inc., were found to comply with the current requirements of UL and are eligible to bear the UL Listing Mark. The UL Listed sumps are suitable for exposure to petroleum products, alcohols, alcohol-gasoline mixtures and soil/ground water environments.

This listing includes, but is not limited to, gasoline, gasoline-ethanol blends at any level of ethanol, gasoline-methanol blends at any level of methanol, 100% ethanol, and 100% methanol. Refer to UL 1316, Standard for Glass Fiber Reinforced Plastic Underground Storage Tanks for Petroleum Products, Alcohols and Alcohol-Gasoline Mixtures, for a list of fluids that were used to investigate the UL Listed sump materials.

If you have any questions, please contact us.

Very Truly Yours,



TIM CREWS (Ext. 42516)  
Staff Engineer  
Hazardous Locations, Gas & Oil

Reviewed by:



WAYNE DOVERSBERGER (Ext. 42072)  
Staff Engineer  
Hazardous Locations, Gas & Oil

