

September 18, 2003

Smith Fibercast
Mr. Jack Bales
5609 Perrin
The Colony, TX 75056

Reference: MH8432

Subject: Closed Secondary Containment Pipe Pressure Rating

Dear Mr. Bales:

This confirms that the minimum pressure rating for a closed secondary containment piping system is 50 psig, as defined in Par. 2.3.2 of the First Edition of UL971, Standard for Nonmetallic Underground Piping for Flammable Liquids (copy attached).

If you have any questions or comments, please contact us.

Very Truly Yours,

Reviewed By:

TIM CREWS (Ext. 42516)
Senior Project Engineer
Hazardous Locations, Gas & Oil

WAYNE DOVERSBERGER (Ext. 42072)
Engineering Group Leader
Hazardous Locations, Gas & Oil